2012 Annual Drinking Water Quality Report Krebs Utility Authority

We're very pleased to provide you with this year's Annual Drinking Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. This report shows our water quality and what it means.

Our water system uses Krebs Lake as the main source of water. During the summer, water is pumped from Lake Eufaula into Krebs Lake to maintain water levels.

If you have any questions about this report or concerning your water utility, please contact the **City of Krebs at 918-423-6519**, **Monday through Friday from 8:00 AM to 5:00 PM.** We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the third Tuesday of every month at the city hall.

Krebs Utility Authority routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2012. (Some of our data may be more than one year old because the state allows us to monitor for some contaminants less often than once per year.) All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk.

WATER QUALITY DATA TABLE

The table below lists all of the drinking water contaminants we detected for the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Parts per million (ppm) or Milligrams per liter (mg/l)

Parts per billion (ppb) or Micrograms per liter (ug/l)

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level (MCL) - The MCL is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG)- The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

2011 WATER QUALITY DATA TABLE

Krebs Utility Authority

			Your	Range		Sample		
Contaminants	MCLG	MCL	Water	Low	<u>High</u>	<u>Date</u>	Violation	Typical Source
Disinfection Byproducts								
Haloacetic Acids (HAA5) (ppb)	NA	60	31	13.7	44.6	2012	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	83	53.4	114.2	2012	Yes	By-product of drinking water disinfection
Turbidity (NTU)								
Lowest monthly % meeting limit	NA	0.3	77.96%	NA	77.96	2012	Yes	Soil runoff
Highest Single Measurement	NA	1	0.75	NA	0.75	2012	NO	Soil runoff
Inorganic Contaminants								
Nitrate [measured as Nitrogen](ppm)	10	10	0.3	0.3	0.3	2012	NO	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Radioactive Contaminants								
Beta/photon emitters (mrem/yr)	0	4	2.5	2.5	2.5	2012	NO	Decay of natural and man-made deposits.
Violations and Evacadances								

Violations and Exceedances

TTHMs [Total Trihalomethanes]

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

Turbidity

Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

What does this mean?

The table shows that our system uncovered some problems this year. The TTHM sample taken for the monitoring period between 1/1/2012 to 3/30/2012 and the sample taken for the monitoring period between 04/01/2012 to 06/31/2012 were out of compliance. TTHMs are a health concern because some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer. We are currently evaluating different chemical treatment options to correct the problem.

The table shows that our system uncovered some problems this year. The turbidity for the monitoring period between 6/1/2012 to 7/312012 was out of compliance Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. To address the problem, we added fifteen bags of activated carbon to our filters. We are also in the process of repairing the flash mixer and air assisted backwash. These repairs will aid in the removal of turbidity.

Additional Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water before we treat it include:

- *Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- *Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- *Pesticides and herbicides, which may come from a variety of sources such as agriculture and residential uses.
- *Radioactive contaminants, which are naturally occurring.
- *Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Krebs Utility Authority is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

Further Information on MCLs

MCLs are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a significant increased risk of having the described health effect.

Please call our office if you have questions.

Contact: Donny James

Address: PO Box 156 Krebs, OK 74554 Phone: 918 423-6519