

WARNING

PRECAUTIONARY BOIL ADVISORY

Water System Name: Krebs Utilities Authority

Public Water Supply ID: OK 1020606

Due to High Turbidity and Low Pressure (problem) in the water system and the potential for contamination as a result of this situation, the drinking water supplied by Krebs Utilities Authority (water system name) may be unsafe for human consumption. As a precaution, **it is advised that the consumers of this water system bring the water to a full, rolling boil for at least one minute before drinking**, consumption, food preparation, baby formula preparation, dish washing, tooth brushing, ice making, wound care, and bathing infants who may ingest bath water. **Alternatively, bottled water or another acceptable water source may be used.**

Important Note: This precautionary boil advisory is not related to the Coronavirus Disease (COVID-19) pandemic, and it is important to continue to wash your hands during the precautionary boil advisory. If soap and water are not available, use an alcohol-based hand sanitizer containing at least 60% alcohol.

Comments: Due to the severe storm system that passed through Monday night, our basement was flooded and most of our pumping equipment was submerged.

We are currently running on backup equipment and will have low pressure for the next few days until the pumps are returned from the motor rebuild shop.

This advisory will remain in effect until further notice. Questions concerning this situation should be addressed to Jonathan Clifton (name) at 918 423-6519 (phone).

Address of the PWS: 5 East Washington

Krebs Oklahoma

County: Pittsburg

Further general information can be found on the DEQ website: www.deq.ok.gov